

Notified body No.1121  
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

## Certificate of constancy of performance

**1121-CPR-BB5006**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### “Birch Plywood Dricon FR Euro Class B: 12mm to 25mm”

Intended use: **Wood Based Panels**

#### Product Performance

Essential characteristics	Performance	Harmonized technical specification
Safety in case of Fire, Reaction to fire	B-s <sub>2</sub> -d <sub>0</sub>	EN 13986:2004 (Classification report No: 184309)

Product Specification (See Page 3)



**Certificate of constancy of performance**

**1121-CPR-BB5006**

Produced for

**International Timber  
West Yard, Trafford Wharf Road, Trafford Park, Manchester M17 1DJ**

and produced in the manufacturing plant(s)

**West Yard, Trafford Wharf Road, Trafford Park, Manchester M17 1DJ  
Wigan Lane, Duxbury, Chorley, Lancashire, PR7 4BU  
London Road, Purfleet, Essex, RM19 1RE  
Earls Road, Grangemouth, Stirlingshire, FK3 8UU  
North Dock, Alexandra Dock, Newport NP20 2WB  
Parkend, Lydney, Gloucestershire, GL15 4JF  
Timber Terminal, King George Dock, Hull, HU9 5QE**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 13986:2004**

under system 1 of AVCP are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on **19/05/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan  
Certification Manager  
Warrington Certification Ltd





## Certificate of constancy of performance

**1121-CPR-BB5006**

### Product Specification

General description	Fire retardant birch ply
Trade name	Dricon FRB
Thickness	12mm-25mm
Density	670kg/m3
Flame retardant trade name	Dricon
Net chemical retention	See Note 1 below
Cycle details	See Note 1 below
Brief description of manufacturing process	Pressure impregnation

**Note 1: The sponsor of the test has provided this information but at the specific request of the sponsor, this information has been omitted from the test report and is instead held on the confidential file relating to this investigation.**

----- End of Certificate -----