

Notified body No.1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of constancy of performance
1121-CPR-BB5010

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“Hardwood Plywood impregnated with Dricon™ flame retardant to Euroclass C: in thicknesses 3.6mm - 25mm inclusive, for use without an air gap”

Intended use: Wood Based Panels

Product Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire, euroclass characteristics	C-s ₂ -d ₀ (Classification report No: 139538)	EN 13986:2004
Durability against aging (Bending Test)	NPD	
Bonding quality	NPD	
Internal bond (Tensile strength)	NPD	
Release of formaldehyde	E1	
Water vapour permeability	NPD	
Airborne sound absorption	NPD	
Sound absorption	NPD	
Thermal conductivity	NPD	
Biological durability	NPD	
Content of pentachlorophenol	NPD	

NPD = No Performance Determined

Product Specification (See Page 3)



Certificate of constancy of performance

1121-CPR-BB5010

Produced for

**International Timber
West Yard, Trafford Wharf Road, Trafford Park,
Manchester M17 1DJ**

and produced in the manufacturing plant(s)

**West Yard, Trafford Wharf Road, Trafford Park, Manchester M17 1DJ
Wigan Lane, Duxbury, Chorley, Lancashire, PR7 4BU
London Road, Purfleet, Essex, RM19 1RE
Earls Road, Grangemouth, Stirlingshire, FK3 8UU
North Dock, Alexandra Dock, Newport NP20 2WB
Parkend, Lydney, Gloucestershire, GL15 4JF
Timber Terminal, King George Dock, Hull, HU9 5QE**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 13986:2004

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **21/07/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan
Certification Manager
Warrington Certification Ltd



Certificate of constancy of performance

1121-CPR-BB5010

Product Specification

General description	Fire retardant hardwood plywood
Trade name	Plywood impregnated with Dricon™ flame retardant to Euroclass C
Thickness	3.6mm-25mm
Density	529kg/m ³ - 823kg/m ³
Flame retardant trade name	Dricon™
Net chemical retention	See Note 1 below
Cycle details	See Note 1 below
Brief description of manufacturing process	Vacuum and Pressure impregnation

Note 1: The sponsor of the test has provided this information but at the specific request of the sponsor, this information has been omitted from the test report and is instead held on the confidential file relating to this investigation.

----- End of Certificate -----