

Notified body No. 1121

Certificate of constancy of performance

1121-CPR-BB5009

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

“Essgee Fireply (Type HR) Dricon™ FR Euro Class B: 9mm to 25mm”

Intended use: Wood Based Panels

Product Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire, euroclass characteristics	B-s ₂ -d ₀ (Classification report No: 139537)	EN 13986:2004
Durability against aging (Bending Test)	NPD	
Bonding quality	NPD	
Internal bond (Tensile strength)	NPD	
Release of formaldehyde	E1	
Water vapour permeability	NPD	
Airborne sound absorption	NPD	
Sound absorption	NPD	
Thermal conductivity	NPD	
Biological durability	NPD	
Content of pentachlorophenol	NPD	

Product Specification (See Page 3)

Certificate of constancy of performance

1121-CPR-BB5009

Produced for

**International Timber
West Yard, Trafford Wharf Road, Trafford Park,
Manchester M17 1DJ**

and produced in the manufacturing plant(s)

**West Yard, Trafford Wharf Road, Trafford Park, Manchester M17 1DJ
London Road, Purfleet, Essex, RM19 1RE
Earls Road, Grangemouth, Stirlingshire, FK3 8UU**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 13986:2004

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **21/07/14** and revised on **10/09/18** and will remain valid to the date given below as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Valid to: **9/9/21**



Paul Duggan
Certification Manager

**Exova (UK) Limited trading as Warrington Certification
Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK**



Certificate of constancy of performance

1121-CPR-BB5009

Product Specification

General description	Essgee Fireply hardwood plywood
Trade name	“Essgee Fireply (Type HR) Dricon™ FR Euro Class B: 9mm to 25mm”
Thickness	9mm-25mm
Density	600kg/m ³
Flame retardant trade name	Dricon
Net chemical retention	See Note 1 below
Cycle details	See Note 1 below
Brief description of manufacturing process	Pressure impregnation

Note 1: The sponsor of the test has provided this information but at the specific request of the sponsor, this information has been omitted from the test report and is instead held on the confidential file relating to this investigation.

----- End of Certificate -----